

H:\2020\2019 - Chaffey Campus Boilers\Sheet\Mechanical\2019_JMP1.01A_SITE_PLAN.dwg Mon, 06 Jun, 2022 4:33pm Plotted by: schrabz



KEYNOTES

* REFER TO EARTHQUAKE VALVE & GAS REGULATOR DETAIL #8/MP6.02 AND PROVIDE SIGNAGE PER CPC 1210.9.3 AND DETAIL 26/A9.10.

- ① CONNECT NEW 2" MPG TO THE NEAREST EX. MPG, CONTRACTOR TO FIELD VERIFY SIZE AND LOCATION ETC.
- ② RUN NEW 2" MPG TO NEW BOILER, INSTALL W/ GAS VALVE AND GAS REGULATOR WITH SHUT OFF VALVE.
- ③ NEW SPACE HEATING BOILER, REFER TO SHEET MP0.02 FOR MORE INFO.
- ④ RUN NEW 2" MPG TO NEW BOILER IN MECHANICAL YARD, INSTALL W/ GAS VALVE AND GAS REGULATOR WITH SHUT OFF VALVE.
- ⑤ RUN NEW 2" MPG TO NEW BOILER IN BASEMENT, INSTALL W/ GAS VALVE AND GAS REGULATOR WITH SHUT OFF VALVE.
- ⑥ RUN NEW 2" MPG TO NEW BOILER IN BOILER ROOM, INSTALL W/ GAS VALVE AND GAS REGULATOR WITH SHUT OFF VALVE.
- ⑦ RUN NEW 2" MPG UP TO THE ROOF TO NEW BOILER, INSTALL W/ GAS VALVE AND GAS REGULATOR WITH SHUT OFF VALVE.

Building : VSS - ADA Project
Scope: Relocating gas line to VSS Building

NOT FOR CONSTRUCTION